

# Neutrino Beamline and Flux Improvements

---

T. Sekiguchi (KEK)  
on behalf of T2K Beam Group


# Contents

---

- **Overview**
- **Hardware improvements**
  - Prospect for 1.3 MW beam power
  - Flux increase by neutrino beamline
- **Flux uncertainty improvements**
  - Reduction of systematic uncertainty




# J-PARC Neutrino Beamline





# Secondary Beamline





- Target Station (includes target and horns)
- Decay Volume
- Beam Dump



# Target Station



**Horn1**



**All equipments inside Helium Vessel can be replaceable** 5

# How to Improve Statistics

---

- **Beam power improvement**
  - Straightforward way to increase statistics.
- **Flux improvement by neutrino beamline**
  - For a given POT, increasing number of produced neutrinos is another way to increase statistics.

# 10 Year Term Plan of Beam Power Improvement

---

- **Beam power improvement plan by 2026**
  - Proton intensity =  **$3.2 \times 10^{14}$  protons/pulse**.
  - Repetition cycle = **1.16 sec.** with new power supply.
- **Can we accommodate such beam power and operation condition?**

Beam Power	# of protons/pulse	Rep. rate
350 kW (current)	1.8x10	2.48 sec.
750 kW (revised)	2.0x10	1.30 sec.
750 kW (original)	3.3x10	2.10 sec.
1.3 MW (proposed)	3.2x10	1.16 sec.



# Current Acceptable Beam Power

Component	Limiting factor	Acceptable value
Target	Thermal shock	3.3x10
	Cooling capacity	0.75 MW
Horn	Conductor cooling	2 MW
	Stripline cooling	0.54 MW
	Hydrogen production	1 MW
	Operation	2.48 sec. & 250 kA
He Vessel	Thermal stress	4 MW
	Cooling capacity	0.75 MW
Decay Volume	Thermal stress	4 MW
	Cooling capacity	0.75 MW
Beam Dump	Thermal stress	3 MW
	Cooling capacity	0.75 MW
Radiation	Radioactive air disposal	1 MW
	Radioactive water	0.5 MW





# Target

- **Thermal shock**

- **Current design based on  $3.3 \times 10^{14}$  ppp**
  - Thermal stress  $\sim 7$  MPa  $\Leftrightarrow$  Tensile strength 37 MPa
  - Degradation of strength due to radiation damage is key issue
- For  $> 3.3 \times 10^{14}$  ppp, **wider beam and larger target diameter** is necessary to reduce thermal shock.

- **Helium cooling**

- Cooling capacity: **designed for 750 kW (+30% margin)**
- **Higher helium flow rate needed for 1.3 MW**
  - **Need upgrade of cooling system for higher beam power.**
- Structure of Ti container may also be modified to accommodate higher He flow and higher pressure.



# Prospect for Hardware Upgrade


---

- **Cooling capacity**
  - Apparatuses themselves can withstand 1.3 MW beam.
  - Improvement of flow rate both for water and helium circulations is needed.
    - Replacement with larger pumps
    - Replacement with larger-size plumbing
    - $\Rightarrow$  They will be feasible but need 1 year for modification.
- **Radiation**
  - Radioactive air
    - Reinforcement of air-tightness  $\Rightarrow$  1.3 MW can be manageable.
  - Radioactive water disposal
    - Enlargement of dilution tank
      - Modification of existing tank  $\Rightarrow \sim 1.3\text{MW}$
      - New facility building for water disposal  $\Rightarrow 2\text{MW}$ 
        - 2 years for construction (no beam stop needed)



# Flux Improvement by Neutrino Beamline

- **Magnetic horn current**
  - 250 kA  $\Rightarrow$  320 kA (rated)
  - **10 % improvement of neutrino flux at far detector**




Courtesy of T.Nakadaira


# Flux Improvement by Neutrino Beamline

- Another benefit of 320 kA operation
  - Low contamination of wrong-sign neutrino background
    - 5~10% reduction at peak ( $E_\nu \sim 0.6$  GeV)

## Neutrino mode



## Anti-neutrino mode





# 320 kA and 1 Hz Operation

- **Requirement**


- Low Joule heating  $\Rightarrow$  narrow pulse
- Short charging time  $\Rightarrow$  energy recovery and low Joule loss
- Low failure risk  $\Rightarrow$  low charging voltage

- **Configuration**

- 1 horn operated by 1 PS  $\Rightarrow$  3 PS in total
  - New power supply developed (2 PS's already produced).
  - Also, low impedance current transfer line newly developed.


- **Timeline**

- Production of the last PS, transformers, part of transfer lines
- Aim to start 320 kA operation from summer 2017.



# Neutrino Flux Prediction

K. Abe *et al.* (T2K Collaboration), Phys. Rev. D 87, 012001 (2013).






- **Neutrino flux at near/far detector simulated w/ MC**
  - Proton interaction inside target  $\Rightarrow$  FLUKA2011
    - propagation of secondary/tertiary particles inside target
  - Propagation/interaction/decay of particles outside target  $\Rightarrow$  GEANT3+GCALOR
- **Hadron production is tuned with NA61/SHINE data**



# Hadron Production Measurement in NA61

- **NA61 measures 30 GeV p+C cross section for T2K**
  - NA61 spectrometer: TPCs + TOFs
  - Carbon target
    - Thin target(2cm)  $\Rightarrow$  primary p+C interactions (60%)
    - Replica target(90cm)  $\Rightarrow$  secondary interactions in target (30%)
- Data for T2K
  - Data collected in 2007, 2009 and 2010
  - Results from 2009 thin target data recently released.



NA61 spectrometer



NIM A701, 99-114 (2013)

# Predicted Neutrino Flux at Far Detector


- Neutrino flux tuned with NA61 data





# Recent Update on Flux Prediction

## Update on flux prediction with NA61 2009 data

- Thin target data
- Larger statistics
- Wider coverage of phase space
- $\pi^\pm$ ,  $K^\pm$ ,  $K^0_s$ ,  $\Lambda$  production data



- Uncertainties at flux peak reduced from 12% to 9%**
- Dominant uncertainty is still from Hadron production modeling.







# Possible improvement of Flux Prediction

- Reduction of Hadron production uncertainties
  - Hadronic interaction length
  - Pion multiplicity } Replica target data
- Pion re-scattering  $\pi^\pm + A \rightarrow \pi^\pm + X$ 
  - Low angle HARP data is used
    - important for low energy wrong sign muon neutrino flux
  - Inclusion of large angle HARP data.


SK: Positive Focussing Mode,  $\nu_\mu$



Courtesy of M. Yu

# Replica Target Measurement

- Replica target data can constrain up to 90% of the flux.
- Data set:  $0.6 \times 10^6$  (2007),  $4 \times 10^6$  (2009),  $10 \times 10^6$  (2010) POT.
  - 2009 data were already released as ph.D thesis of A. Heasler. [CERN-THESIS-2015-103](#)
- Multiplicities of particles exiting the target in bins of Z, p,  $\theta$  are measured.
  - These uncertainties are replaced by systematic uncertainties from the replica target measurement
- Comparison to thin target data partly agrees well, but not perfect.




# Flux Tuning with Replica Target Data


- **Tuning of flux using the 2009 replica target data (A. Heasler)**
  - Flux weighted by ratio of the measured over the simulated particle production from the replica target

$$w(p, \theta, z) = N_{NA61}^{corr}(p, \theta, z) / N_{T2K}^{sim}(p, \theta, z)$$

Ratio of the thin target tuned flux over the replica target tuned flux



Systematic uncertainty on the fraction of the flux tuned by the replica target multiplicities



- **Further improvements on the replica target measurement**
  - Better precision w/ more statistics of 2010 data.
  - Further reduction by improving backward extrapolation of tracks to the target by bringing it closer to the spectrometer.




# Summary

---

- **Beam power upgrade**
  - 1.3 MW beam until 2026.
  - Neutrino beamline will be upgraded for 1.3 MW beam.
- **Neutrino flux improvement by 320kA operation**
  - 10% flux gain
  - Hardware upgrade done by summer 2017 if budget is timely approved.
- **Improvement on the flux uncertainties**
  - Flux update with NA61 2009 data:  $12\% \Rightarrow 9\%$
  - 2009 replica target data was released.
  - Further reduction of flux uncertainties can be achieved.

# Supplemental Slides

# Where We Are Now



- Achieved beam power so far
  - 371 kW at maximum.
  - **335~350 kW continuous operation**



# Stripline Cooling


---

- **Forced helium flow for stripline cooling.**
  - Large heat deposit at Horn2 (due to defocused pions)
  - Insufficient helium flow rate for Horn2. → 0.54 MW
  - **Double flow rate for Horn2 → 1.25 MW**
- **Water-cooled striplines**
  - Necessary when beam power goes beyond 1 MW.
  - Under conceptual design.

	Horn1	Horn2	Horn3
Heat flux per stripline plate (J/m			
Total (Beam + Joule)	214	1066	141
Acceptable Beam Power			
w/ current flow rate	2.10	0.54	3.46
w/ double flow rate	-	1.25	-


# Hydrogen Production Problem

- $\text{H}_2$  production by water radiolysis.
- **Hydrogen recombination system**
  - Forced helium circulation **inside** Horns drastically improved  $\text{H}_2$  removal.
  - 2-week continuous operation w/ 335 kW  $\rightarrow \text{H}_2 < 0.7\%$ .
  - Current limit : Low  $\text{O}_2$  density due to resolution in water.
    - **1 MW beam is acceptable** (w/ keeping  $\text{H}_2$  density  $< 2\%$ )
  - Degasifier system will be introduced for higher recombination efficiency.





# Target Station / Decay Volume / Beam Dump


- **Tolerance for thermal stress**
  - Designed for 4 MW (TS, DV) and 3 MW (BD) beam
    - No access is allowed after beam exposure.
- **Cooling**
  - Cooling capacity designed for 750 kW.
  - Need upgrade of cooling system for higher beam power.



Decay Volume



Beam Dump






# Radio-active Water Disposal


- **Radio-active water**
  - $^7\text{Be}$ : 99.9% removed by Ion Exchangers.
  - $^3\text{T}$ : Diluted many times (80 times/year)
- **Limited dilution tank size  $\rightarrow$  0.5 MW**
  - Highly-activated water can be taken by tanker truck.
    - 750 kW will be accepted.
  - For BD/DV downstream cooling water, connection equipment for tanker truck was prepared and tested.

## Water disposal system at TS



# Radio-active Water Disposal

- For beam power  $> 750$  kW, construction of larger dilution tanks is necessary.
- New facility building for radio-active water disposal
  - New dilution tanks is designed for **2 MW**.
  - We are applying budget for this facility.



# Acceptable Beam Power

---

- **Target and Beam Window**
  - Thermal shock :  $3.3 \times 10^{14}$  ppp
  - Helium cooling : 750 kW
- **Horn**
  - Horn conductor cooling : 2 MW
  - Stripline cooling : 540 kW  $\rightarrow$  1.25 MW
  - Hydrogen production : 1 MW
  - Operation : 0.4 Hz & 250 kA  $\rightarrow$  1 Hz & 320 kA
- **He Vessel / Decay Volume / Beam Dump**
  - Thermal stress : 4 MW (HV, DV), 3 MW (BD)
  - Cooling capacity: 750 kW
- **Radio-active air : 1 MW**
- **Radio-active water disposal: 0.5 MW  $\rightarrow$  0.75 MW  $\rightarrow$  2 MW**